



RAdata, LLC
 27 Ironia Road, Unit 2
 Flanders, NJ 07836
 973-927-7303 Phone
 973-927-4980 Fax

Customer: The Study Hall
 100 Frank East Rodgers Boulevard North
 Harrison, NJ 070290000

Laboratory Results

Sample Number	Sample Location	Collected By
0422-9590	100 Frank East Rodgers Boulevard Nor	Dan, Nigara

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0422-9590	4/8/2022 7:32:00 AM First Floor Red Room Kitchenette Sink	4/12/2022 9:13:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9590-1	4/8/2022 7:32:00 AM First Floor Red Room Kitchenette Sink	4/12/2022 3:23:00 PM	Copper	0.0750 mg/l	1.3 mg/L	Std Method 3111B
0422-9590-2	4/8/2022 7:35:00 AM Basement Kitchen Sink	4/12/2022 9:13:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9590-2	4/8/2022 7:35:00 AM Basement Kitchen Sink	4/12/2022 3:23:00 PM	Copper	0.0750 mg/l	1.3 mg/L	Std Method 3111B
0422-9590-3	4/8/2022 7:39:00 AM First Floor Bathroom Boys Sink	4/12/2022 9:13:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9590-3	4/8/2022 7:39:00 AM First Floor Bathroom Boys Sink	4/12/2022 3:23:00 PM	Copper	<0.0500 mg/l	1.3 mg/L	Std Method 3111B

**The parameters tested on this report PASSED NJ
 Drinking Water Standards.**

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

Reviewed and Approved by:

Ashley Shann, Laboratory Manager Designee

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, April 18, 2022

NJDEP Laboratory Certification # 14006

Page 1 of 1