

December 27<sup>th</sup>, 2023

The Study Hall  
100 Frank East Rodgers Blvd North  
Harrison NJ 07029

**PROPERTY LOCATION:** The Study Hall  
100 Frank East Rodgers Boulevard North

**WATER ANALYSIS REPORT**

\*Enclosed please find the water analysis report from the lab for the above listed property. As indicated in the report, some of the parameters tested **DO** comply to NJ DEP standards. Please review the reports carefully and feel free to contact our office if you have any questions.

The following parameters were tested:

Lead/Copper – 3 Locations

\*\* indicates parameters that do not meet NJ DEP standards.

*When submitting reporting forms to any organization, RAdata strongly recommends you retain a copy for your files. RAdata & the labs retain copies if something should happen to your copies.*

Thank You,



Stephanie Leenstra  
Field Services Manager



RAdata, LLC  
 27 Ironia Road, Unit 2  
 Flanders, NJ 07836  
 973-927-7303 Phone  
 973-927-4980 Fax

**Customer:** The Study Hall  
 100 Frank East Rodgers Boulevard North  
 Harrison, NJ 070290000

## Laboratory Results

Sample Number	Sample Location	Collected By				
1223-5735	100 Frank East Rodgers Boulevard Nor	Dan, Nigara				
Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
1223-5735	12/19/2023 7:09:00 AM Classroom E Hand Wash Sink	12/21/2023 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1223-5735-1	12/19/2023 7:09:00 AM Classroom E Hand Wash Sink	12/21/2023 10:50:00 AM	Copper	0.0870 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1223-5735-2	12/19/2023 7:11:00 AM Classroom C Kitchen Tap	12/21/2023 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1223-5735-2	12/19/2023 7:11:00 AM Classroom C Kitchen Tap	12/21/2023 10:50:00 AM	Copper	0.0520 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1223-5735-3	12/19/2023 7:13:00 AM 2nd Floor Boys Bathroom Tap	12/21/2023 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1223-5735-3	12/19/2023 7:13:00 AM 2nd Floor Boys Bathroom Tap	12/21/2023 10:50:00 AM	Copper	<0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B

**The parameters tested on this report PASSED NJ  
 Drinking Water Standards.**

*This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.*

Reviewed and Approved by:

Ashley Shann, Laboratory Manager Designee

# MCL - Maximum Contaminant Level

ND - Not Detected

\* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

\*\* If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

